

Larry

Paul

Pam

Jerry

Gary

Imo

Joe

Art: Route - Cy

cys to:

Forward - Toss

File:

C O N F I D E N T I A L

PROJECT COORDINATION NOTE

PROJECT : New Building Communications
Program

PCN : #24

25X1 AUTHOR :

Date: 11 April 1984

APPROVAL :

SUBJECT : ✓ Fire Protection in Computer Areas of the New
Headquarters Building

25X1 DISTRIBUTION:

1. The following are the requirements for operations shutdown in the New Building computer area in the event of alarm conditions.

2. The options for automatic shutdown of operations are required only when water flow is detected in the sprinkler system. This should shut down power to both computer equipment and air-handling equipment as the result of the alarm condition.

3. A manual shutdown is required for other alarm conditions.

25X1 4. Should additional information be required concerning require-
25X1 ments for fire protection in the computer area of the new head-
quarters building, please contact [redacted] OC/DND/HFG/IMB on
[redacted]

25X1 WARNING NOTICE - INTELLIGENCE
SOURCES OR METHODS INVOLVED

C O N F I D E N T I A L